


# FIRE DOOR STOP TOP SYSTEM

CFD-001-T

- > UL listed for excessive clearances and gaps
- > UL tested and listed to allow for excessive clearances up to 1/2" on steel doors
- > UL fire-rated for up to 180 minutes
- > Maintains your fire door assembly's existing fire rating
- > Tested under NFPA-252 with hose stream, ANSI/UL 10B with hose stream, UL 10C, CAN/ULC S104-10



- ① Crown Fire Door Stop Top System for Steel Doors
- ② Intumescent Smoke Seal



**R27658**  
MISCELLANEOUS FIRE  
DOOR ACCESSORY